




NEW ACCESS GATE AS SPECIFIED



TYP. BOUNDARY FENCE PANEL

1:50

NOTES

- 1. DO NOT SCALE FROM THIS DRAWING.
- 2. ALL LEVELS IN METRES UNLESS NOTED OTHERWISE ON DRAWING.
- 3. ALL DIMENSIONS AND LEVELS TO BE CHECKED ON SITE PRIOR TO UNDERTAKING ANY WORKS, ORDERING MATERIALS OR FABRICATING ANY COMPONENTS
- 4. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL OTHER RELEVANT ENGINEER'S AND ARCHITECT'S DRAWINGS AND RELEVANT SPECIFICATION CLAUSES.
- NEW 2.0m HIGH BOUNDARY FENCE TO BE POWDERCOATED WELDED MESH SECURITY FENCE ZINC COATED TO BS EN 10244-2:2009 CLASS A & POWDERCOATED TO BS EN 13438, COLOUR : GREEN
- NEW SINGLE SWING ENTRANCE GATE TO BE 2.0m HIGH GAVANIZED TO BS EN 1461 AND POWDER COATED TO BS EN 13438, COLOUR : GREEN RAL 6005.

KEY

DENOTES NEW BOUNDARY FENCE AS SPECIFIED



	POI	11.07.22	FIRST ISSUE								
ELITY	REV	DATE	DESCRIPTION	Org.	Chica	Appld	Auth				
INIC CTATILE.											

HUWS GRAY, BRYN CEGIN INDUSTRIAL ESTATE, LLANDYGAI

PROPOSED SITE BOUNDARY

017321 CCE ZZ ZZ 40:40:01 C 15


0004 S1 P01


CONSULTING ENGINEERS


CADARN Consulting Engineers Ltd, Suite B, Anglesey Business Centre,

Bryn Cefni, Llangefni, LL77 7XA


Tel: 01407 730912 E-mail: admin@cadarnconsulting.co.uk











NOTES

- 1. DO NOT SCALE FROM THIS DRAWING.
- ALL LEVELS IN METRES UNLESS NOTED OTHERWISE ON DRAWING.
- 3. ALL DIMENSIONS AND LEVELS TO BE CHECKED ON SITE PRIOR TO UNDERTAKING ANY WORKS, ORDERING MATERIALS OR FABRICATING ANY COMPONENTS
- 4. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL OTHER RELEVANT ENGINEER'S AND ARCHITECT'S DRAWINGS AND RELEVANT SPECIFICATION CLAUSES.
- LIGHTING COLUMNS AND BRACKETS SHALL COMPLY WITH MCHW1 CL. 1302.
- 6. LIGHTING COLUMNS AND BRACKETS SHALL BE PROTECTED AGAINST CORROSION TO THE REQUIREMENTS OF MCHIW (CL. 1995 FOR GALVANISED COLUMNS AND/OR CL. 1921 FOR PAINTED COLUMNS AND/OR CL. 1921 FOR PAINTED COLUMNS ABOUND THE OF EQUAL APPROVED INSTALLED STRCTLY IN ACCORDANCE WITH MANUFACTURES INSTRUCTIONS INSTRUCTIONS
- BACKFILLING FOUNDATIONS SHALL COMPLY WITH MCHW1 CL. 1305.
- CABLE ENTRY HOLE SHALL BE SMOOTH AND HAVE A MINIMUM WIDTH OF 50mm.
- . A DUCT EQUAL IN SIZE TO THE WIDTH OF THE CABLE ENTRY HOLE SHALL BE MADE THROUGH THE CONCRETE FILLING TO MCHWI CL. 1305.4.
- 10. LANTERN TO BE IP66 RATED 2 MODULE LED WITH DIE-CAST/PROFILED ALUMINIUM HOUSING, ABACUS CHALLENGER 1 4000K LED, REF, ALG-90S/R OR EQUAL APPROVED. TO BE INSTALLED STRICTLY IN ACCORDANCE WITH MANUFACTURERS INSTRUCTIONS, TILT-0, CANT-0, CRI Ra70

51		701	11.07.22	FIRST ISSUE				
SUTTABLE	шт	REV	DATE	DISCRIPTION	Org.	Chave	Apple	Aus).
TOP A WIT	NG	STATE	ъ.					

DRAWING STATUS:

HUWS GRAY, BRYN CEGIN INDUSTRIAL ESTATE, LLANDYGAI

DRAWING TITLE:

PROPOSED SECURITY LIGHTING

RAWING No:



Address: CADARN Consulting Engineers Ltd, Suite B, Angiesey Business Centre, Brow Ceffsi

KA E-mail:

Tel: 01407 730912 E-mail: admin@cadamconsulting.co.uk

© CADARN CONSULTING ENGINEERS LTD 2022

